

TEST REPORT : **DETERMINATION OF LOOSE AND COMPACTED BULK DENSITY**
BS EN 1097-3:1998

REPORT No.: 601156 / 65010.1.1.1 CLIENT: Land Logical Dartford Ltd

SAMPLE No.: 105949 ADDRESS: Stone Power Plant

CLIENT REF.: Stw/2802/01 SITE: Willow Hall Lane, Thorney

DATE RECEIVED: 28/02/2019 SUPPLIER: Site Won

DATE SAMPLED: 28/02/2019 MATERIAL: Sharp sand

DATE TESTED: 06/03/2019 NOMINAL SIZE: 4mm

TESTED BY: Joe Marston LOCATION: Stockpile Off Belt

ACCEPTABLE STANDARD : Contract Specification SAMPLING CERTIFICATE: Available


RESULT:

LOOSE BULK DENSITY :	RESULT
Test Specimen 1	1.71 Mg/m ³
Test Specimen 2	1.76 Mg/m ³
Test Specimen 3	1.69 Mg/m ³
LOOSE BULK DENSITY VALUE (r_b) : (Mean of Three Results)	1.72 Mg/m³

REMARKS:

For and on behalf of CET

Remaining sample will be retained for a minimum of 28 days from date of report.

Fred Fall - Senior Laboratory Supervisor
Freddie Fyfe- Site Quality Supervisor
Jack Maxwell - Assistant Laboratory Manager